



May 15, 2006

QUANICS, INC.
BRIAN BORDERS
PO BOX 1520
CRESTWOOD KY 40014

Re: Description: SEWAGE TREATMENT APPARATUS (also see SEWAGE TANKS)
Manufacturer: QUANICS, INC.
Product Name: PRESSURE DISTRIBUTION PRESSURE FILTER
Model Number(s): PDS-PF-1.5, PDS-PF-1.5-AP, PDS-PF-2.0 and PDS-PF-2.0-AP
Product File No: 20060187

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2010.

This approval supersedes the approval issued on April 19, 2005, under product file number 20050114.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20050114.

This approval is contingent upon compliance with the following stipulation(s):

- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- The sizing calculations of the pressure distribution network must include head loss for this product based on flow rate, model and manufacturer pressure loss chart.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wisconsin.gov